

April 10<sup>th</sup>, 2012

Mr. Arvind Patel  
Director, Engineering  
Psiber Data Pte. Ltd.  
9 Jurong Town Hall Road, #03-05, iHUB  
Singapore 609431  
Tel: 65-6569 6019  
Email: [apatel@psiber-data.com](mailto:apatel@psiber-data.com)  
<http://apen.psiberdata.com>

Subject: Psiber Data WireXpert™ Approval

Dear Arvind,

TE Connectivity is pleased to announce the approval for use of the WireXpert WX4500-FA effective immediately under the conditions of this letter. This approval is based upon evaluation of the WireXpert versus network analyzer by Tyco Electronics AMP España S.A.U. Labs according to standard IEC 61935-1 Ed.3 requirements.

WireXpert is approved for use in both Permanent Link and Channel certification testing with all of our Class F, Category 6A/Class E<sub>A</sub>, Category 6/Class E and Category 5E/Class D system warranties.

The following configuration of WireXpert is required:

WX4500 software version 4.0.9 or higher  
ReportXpert™ software version 4.0.9 or higher

Channel testing for Class F	WX_AD_TERA_CH2 – pair of Class FA TERA channel adapters
Permanent link testing for Class F	WX_AD_TERA_LKIT2 – Permanent link testing kit for TERA interface for Class F
Channel testing for Category 6A/Class E <sub>A</sub> , Category 6/Class E and Category 5E/Class D	WX_AD_6ACH2 - pair of CAT 6A channel adapters
Permanent Link testing for Category 6A/Class E <sub>A</sub> , Category 6/Class E and Category 5E/Class D	WX_AD_6ALKIT2 – pair of CAT 6A permanent link kits: each consisting of a CAT 6A permanent link adapter WX_AD_6ALINK and a Permanent Link test cord WX_AC_6ALCORD

We will be notifying our global listing of authorized installers of this approval and will update our Field Testing requirements to include the WireXpert.

Looking forward to our continued partnership.

Sincerely,



Albert Font <sup>PMP</sup>  
Product Manager EMEA, India & ANZ